

Iluminat exterior arhitectural la Primaria orasului Sfantu Gheorghe

2010 august



Cladire 1/1 sala
festiva



AIL tip B



AIL tip A



AIL tip C




Cod	Denumire	Can.	Putere total in W
-----	----------	------	----------------------

Cladire 1/1 sala festiva

B	AIL 38W	1	38,00
A	AIL 5 x 3 W LED	18	270,00
C	AIL 35 W	9	315,00

Putere totala cu pierderi de 20%

0,75kW



Cladire ½ intrare principala



AIL tip A



AIL tip D



AIL tip B



AIL tip A



AIL tip E



AIL tip C



Cod	Denumire	Can.	Putere total in W
-----	----------	------	----------------------

Cladire 1/2 intrare principala

A	AIL 5 x 3 W LED	4	60,00
D	AIL 35 W	5	175,00
B	AIL 38W	4	152,00
A	AIL 5 x 3 W LED	13	195,00
E	AIL 20 W	11	220,00
C	AIL 35 W	11	385,00

Putere totala cu pierderi de 20%

1,42kW



Cladire 1/3 birouri



AIL tip F



AIL tip G



Cod	Denumire	Can.	Putere total in W
-----	----------	------	----------------------

Cladire 1/3 birouri

F	AIL 20 W	13	260,00
G	AIL 20 W	12	240,00

0,60kW

Putere totala cu pierderi de 20%